Air Source Heat Pump Calculations following demand reduction of Gas Consumption - No data for Sports Pavilion, and Leisure Centre to be assessed nearer 2030

1) Total (ballpark) T/CO2e savings from replacement of gas heating with Air Source Heat Pumps <u>304.52</u>		<u>304.52</u>	<u>66.38%</u>	From a total CO2e emissions of all gas heating of			<u>458.74</u>	Leaving 165.49 to be offset b	y PV, thus re			
2) HP solution reduces annual running costs (before any solar PV added) of <u>£6,510</u>		<u>£6,510</u>	If Solar PV installed to offset remaining emissions, savings from the avoided cost of imported elec (based on current costs):				<u>£53,331</u>	With potential additional revenue from exporting excess generated energy of: <u>£7,202</u>				
	TBC Offices	TBC Office comments	Roses Theatre	Theatre comments	Hat Shop	HAT Shop comments	5 x Domestic	: Domestic Houses comments	Leisure Centre	Leisure Centre comments	Totals	
Current Annual Heat Demand - Gas in kWh	568,569	Represents current consumption for whole building	233,897		11,794		71,428	Data based on EPC extrapolation	1,632,377	Detail of all data is contained in	2,518,065	
Demand Reduction (DR) from time savings	74,161	15% from optimisation of heating to match demand through weather controls	120,835	Main Air Handling Unit currently running 24/7. Est 80% of all usage. 58 hrs p/w req'd	5,307	45% possible from optimisation of heating to match demand through weather controls	22,657	Total savings have been extrapolated to include property for which no data available, and is 79% of total savings based on DEFRA published consumption (2017)	0	Scenario 2 (TLC HP&PV), but replicated here to show impact of all Heat Pump solution opportunity	222,960	
Demand Reduction from temp savings (after savings from time reductions applied)	82,491	20% reduction (2.5oC) would still provide in office temp of 21	0	No savings estimated as controls broken	0	Control Temps set high but necessary based on building type	N/A		0		82,491	
New potential demand from DR savings	411,916	Savings in order of 30% minimum anticipated	113,062	Minimum 50% savings available - likely to be higher	6,487		48,771		1,632,377		2,212,613	
Demand after Combustion losses removed	288,341	Old plant generously assumed to be 70% efficient	79,143	Old plant generously assumed to be 70% efficient	4,541	Old Nemeha Quinta Boiler - 70% efficient at best	t 39,017	Taken 80% Boiler Efficiency	1,469,139	Taken 90% Boiler Efficiency	1,880,182	
COP of A-2-A	4	50/50 split of demand	4	80% A-2-A system 20%	N/A		N/A		4			
COP of A-2-W	3	pump technologies	3	A-2-W estimated	3	100% A-2-W	3	100% A-2-W	3			
Demand of A-2-A	36,043		15,829		0		0		257,099	70% of demand Estimated	308,971	
Demand of A-2-W	48,057		5,276		1,514		13,006		146,914	30% of demand estimated	214,766	
Total New Heat Demand	84,100		21,105		1,514		13,006		404,013		523,737	
Assumed cost of gas/kWh (incl. Climate Chage Levy	2.65p/kWh	Taken from billings data	3.35p/kWh	No costs available, unit	4.8p/kWh	No costs available,	4.5p/kWh	No costs available, unit rates estimated	2.24		2.51	
Assumed cost of elec/kWh (incl. Climate Chage Levy	15.85p/kWh	prior to discounts	17p/kWh	rates estimated	17p/kWh	unit rates estimated	17p/kWh		12.8		13.58	Average £/kWh based on total consumption and total
Estimated current annual operating cost	£15,067	Based on current tariffs	£7,836		£566		£3,214		£36,565		63,248	estimated costs
Estimated annual operating cost of new system	£13,330	and exclusive of VAT	£3,588		£257		£2,211		£51,714		71,100	
Potential revenue - Renewable Heat Incentive (2.75p/kWh)	£2,313	Based on 2019/20 rates	£580	Based on 2019/20 rates	N/A		£358	Based on 2019/20 rates	£11,110		14,403	
Total potential annual cost benefit	£4,050		£4,828		£309		£1,361		-£4,038		6,510	
Current Annual Emissions from heating system	118.13	Tonnes/CO2e p.a for whole building	48.59		2.45		14.84		339.14		458.74	data apportioned for only TBC area of office.
Proportionate Annual Emissions for Council based on approtioned floor area	53.71		N/A		N/A		N/A		N/A			
Estimated Annual Emissions from Heat Pump system based on 2019 emissions	26.57		6.67		0.48		4.11		127.66	using 2019 conversion factors	<u>165.49</u>	Reduces to 154.22 when apportioned area for TBC office applied
Estimated emissions from Heat Pump System applying projected 2030 CF data	8.16		2.05		0.15		1.26		39.19		<u>50.80</u>	Factors in all TBC Building as extent of tenant occupied area in 2030 is not known
Tonnes CO2e annual saving	91.55	77.50%	<u>41.93</u>	86.28%	<u>1.97</u>	<u>80.48%</u>	<u>10.73</u>	80.48%	<u>211.48</u>	62.35% reduction in emissions	304.52	

CO2e savings allocating occupied floor area of t 38.41

41.95% total office area allocated to council, so actual saving is <u>32.5%</u>

N/A